GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Water Resources Department – Industrial Water Supply- Renewal of permission to M/s Satyamaharshi Power Corporation Limited, Muthaiahpalem (V), Amaravathi (M), Guntur District, for drawl of 1250 KLD or 0.016 TMC or 0.51 Cuses of water from Krishna River for a period of 10 years w.e.f. 12.11.2017 to 11.11.2027 - Accorded - Orders – Issued.

WATER RESOURCES (REFORMS) DEPARTMENT

G.O.Ms.No.25 **Dated:15.03.2024**

Read the following:

1. G.O.Ms No. 81, I&CAD (PW: Reforms) Dept., dt. 31.12.2011.
2. From the Engineer-in-Chief (I), WRD, Lr. No.ENC(I)/EE/DEE 1/ AEE 2/IWS/Satya Maharshi Power Ltd., dt. 04.04.2022.
3. Govt. Memo No. ICD01-COOR0MISC/70/Reforms/2023-1, dt. 04.07.2023.
4. From the Engineer-in-Chief (I), WRD, Lr. No: ENC(I)/EE/DEE1/ AEE2/IWS/Satya Maharshi Power Corporation Ltd., dt: 04.03.2024.

****

O R D E R

In the letters 2nd and 4th read above, the Engineer-in-Chief (Irrigation), Water Resources Department, has furnished a detailed proposal based on the report of the Chief Engineer, Krishna Delta System, Vijayawada and recommended to Government to accord renewal of permission to M/s Satyamaharshi Power Corporation Limited, Muthaiahpalem (V), Amaravathi (M), Guntur District, for drawl of 1250 KLD or 0.016 TMC or 0.51 Cuses of water from Krishna River for a period of 10 years w.e.f. 12.11.2017 to 11.11.2027, subject to the following terms and conditions :

1) The concurrence of the District Collector, NTR District, for the proposals has to be obtained before drawing the water and take up the work.
2) The water can be spared only subject to the availability of water in the Krishna River.
3) The Entire cost of construction of intake well, pump house, pipe lines, excavation etc. should be borne by the industry only.
4) Water Meters or suitable measuring devices should be installed by the industry at their own cost to measure the water consumed and should be made available to the Departmental Authorities and their representatives of the user shall be present at all times of inspection. The water meter shall present at all times of inspection. The water meter shall be periodically calibrated and kept sealed. The Department will specify the period of calibration.
5) The industry should pay the water rate at the existing rates and subject to revision by the Government from time to time. In case of failure to pay water rate/royalty the permissions to draw water shall stands cancelled.
6) The industry shall obtain the prior concurrence from concerned Departments for laying of pipelines and for crossings etc. wherever and whenever necessary.
7) No field bodhi or pipeline shall be taken through or along with Government land without approval of Government and if permission accorded by the Government the lease should be paid as fixed by Government only.

8) The industry should make their own arrangements to dispose the treated effluents as per norms of A.P Pollution Control Board in their premises only and should obtain prior permission if any needed from government to dispose treated effluents in their natural sources. Necessary clearance from the A.P Pollution Control Board is to be obtained in this regard by the firm before drawl of water from the source.
9) The water Resources Department reserves the right for cancellation of the permission without assigning any reasons thereof.
10) The water Resources Department is no way responsible for non-supply of water due to any reasons.
11) The industry must acquire private land for installation of pumping arrangements. If the industry proposes to utilize Government land for installation of pump house, necessary permissions is to be obtained from the Government for leasing the land and the lease amount as fixed is to be paid by the industry.
12) The industry must strengthen the river margin 100m. from the toe to the Krishna River flood bank.
13) The industry has to lay CC (1:4:8) before laying the pipeline and CC (1:2:4) over the pipeline refill the pipeline with proper soils and consolidate the banks as directed by the Department.
14) The industry has to construct CC walls to avoid leakage at pipe line crossing.
15) The water drawn Krishna River should be utilized for the purpose for which the permission is granted. Any misuse on this account shall entail cancellation for the permission without any notice and liable for imposition of penalty.
16) The industry should follow the Revenue Board standing orders.
17) The industry shall pay security deposit at 5% on 10 years water charges for which permission is granted.
18) The industry shall pay one-year water charges as advance and any amount due to the Department before entering in to agreement.
19) The industry has to conclude the agreement with the officers concerned of water Resources Department.
20) The industry shall abide by R.C Act -1884 and any other condition laid down by the Government/ Department from time to time.
21) The industry should make its own arrangements for summer storage in their premises only.
22) The industry has to pay the water charges for the estimated quantity in advance at the starting of the financial year i.e. before 10th April every year as per BSO.
23) Under any circumstances, the consumptive utilization should not exceed the quantum of water allotted by the Government.
24) The proposed drawl for this plant should not affect lower riparian rights (LRR) and Upper riparian rights (URR) in any manner.
25) The Department is no way responsible for any damages that may occur to the off-take point due to floods in Krishna River or on an account of any other reasons.
26) The permission does not confer any riparian right to the industry.
27) Non-adherence to any of the above conditions by the industry will entail cancellation of the permission.
28) The firm has to produce the relevant records for Departmental verification at the end of each quarter periodically.
29) A detailed plan showing the location of intake arrangements, pump house, alignment of pipe line and conveyance system should be furnished to the Department, for approval.
30) The concerned Executive Engineer will be responsible for enforcing the conditions.

2. Government, after careful examination of the matter, hereby accord renewal permission to M/s Satyamaharshi Power Corporation Limited,

Muthaiahpalem (V), Amaravathi (M), Guntur District, for drawl of 1250 KLD or 0.016 TMC or 0.51 Cuses of water from Krishna River for a further period of 10 years w.e.f. 12.11.2017 to 11.11.2027, subject to the terms and conditions as mentioned at above para.

3. The Engineer-in-Chief (Irrigation), Water Resources Department, Vijayawada, the Chief Engineer, Krishna Delta System, Vijayawada, Collector & District Magistrate of Guntur District and the Collector & District Magistrate of NTR District shall take necessary action accordingly.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

SHASHI BHUSHAN KUMAR
PRINCIPAL SECRETARY TO GOVERNMENT

To
The Engineer-in-Chief (Irrigation), Water Resources Department,
Andhra Pradesh, Vijayawada.
The Chief Engineer, KDS, WRD, Vijayawada.
The Collector & District Magistrate Guntur District, Guntur.
The Collector & District Magistrate, NTR District, Vijayawada.
The Managing Director, A.P. Pollution Control Board, A.P, Vijayawada.
Copy to:
The Managing Director, M/s Satyamaharshi Power Corporation Limited,
Muthaiahpalem (V), Amaravathi (M), Guntur District
The P.S. to the Hon'ble Minister for Water Resources.
The P.S. to the Prl. Secretary to Government, Water Resources Department.
The P.S. the Secretary to Government, Industries Department.
SF/SC.

//FORWARDED::BY ORDER//

SECTION OFFICER